

PUBLIC NOTICE is hereby given that the Pittsburgh Water and Sewer Authority has prepared an Act 537 Plan Special Study for the 31st Ward of the City of Pittsburgh. This plan is for the sole purpose of addressing the PA DEP Act 537 requirements to complete a Special Study for the 31st Ward Pump Station and Appurtenances Project.

Pittsburgh Water and Sewer Authority evaluated the following alternatives:

- Alternative 1: Pump sanitary sewer inflow to MH184J022 and discharge to ALCOSAN

- o Alternative 1 – A: Rehabilitation in kind of both The Rodgers Street and Mifflin Road Pump Stations

- o Alternative 1 – B: Rehabilitate both Pump Stations and force mains.

- o Alternative 1 – C: Rehabilitate both Pump Stations with separate force mains.

- o Alternative 1 – D: Rehabilitate both Pump Stations and add an equalization tank to the Rodgers PS site.

- o Alternative 1 – E: Eliminate the Rodgers PS, rehabilitate the Mifflin Road PS, and add an EQ tank to the Mifflin Road PS site.

- Alternative 2: Eliminate Mifflin Road Pump Station and rehabilitate Rodgers Pump Station, splitting flow between ALCOSAN and West Mifflin Sanitary Sewer Municipal Authority (WMSSMA)

- Alternative 3: Bypass and eliminate both Pump Stations and discharge flow from 31st Ward to WMSSMA sewer system.

The selected Alternative for this plan is Alternative 1 – E. Upon publication of this notice, a 30-day review and comment period is in effect.

Anyone wishing to review and/or comment may do so during this 30-day period. The Special Study will be made available for review at the Pittsburgh Water and Sewer Authority Office. Comments will be accepted in writing at the Pittsburgh Water and Sewer Authority Office, Attn: Toby Stutzman, 1200 Penn Ave, Pittsburgh, PA 15222.